

June 9, 2020

Re: TALBOT COUNTY PUBLIC SCHOOLS SECURITY VESTIBULE INSTALLATION
(PROJECT #20.0800-1) REQUEST FOR PROPOSAL (RFP) ADDENDUM

ADDENDUM #3:

The RFP document for the aforementioned project, advertised on May 11, 2020, is being amended and/or clarified based on the following information:

A. Door Hardware Clarification:

- Easton Middle School - No electrified hardware is required for the inner vestibule doors (101-A & 101-B). They will be controlled manually, as indicated on the hardware schedule in specification section 087100R.
- St. Michaels High School - The existing opening (#101) is 37" wide. The contractor shall provide appropriate stops and infill to insert a 36" door without substantial modification to the existing structural aluminum framing.

- B. Security Systems Equipment Vendor – In recent years TCPS has utilized the following vendor to maintain our security systems and perform security equipment installations: *ARK Systems, 9176 Red Branch Rd, Columbia, MD 21045*. This reference is for informational purposes only, and shall not be considered a requirement to utilize said vendor when submitting a response to this solicitation.

END OF ADDENDUM #3